From:	Danny Mapili - WPD-C
To:	Philip Mudd
Cc:	tony.lopacki@gsa.gov; Lynn.Goldfarb@perkinswill.com; Ruschaupt, Chris @ Washington DC (Chris.Ruschaupt@cbre.com); Terry Lamb Sr.; Joshua Hill; Thomas.Gregory@perkinswill.com
Subject:	Re: FW: Water filter specifications
Date:	Thursday, April 07, 2016 7:37:57 AM

Chris,
Let's talk about this quickly at today's meeting. Thanks

Danny C. Mapili
Project Manager
Lease Projects Division
Office of Design and Construction
NCR-PBS
U.S. General Services Administration
P 202-219-0376 | M 703-678-8289

On Thu, Apr 7, 2016 at 7:29 AM, Philip Mudd <Philip.Mudd@ferc.gov> wrote:

> Please make sure these details get added to the drawings. The CUNO brand that is aqua-pure's AP-11T has failed repeatedly, we changed to the EVERPURE E-Series housing. The "O" rings do not fail, they have a much more substantial construction and a sturdy mounting system. The 4 west galley has an example and I have sample of both the filter & the housing. Our building engineers prefer the EVERPURE E-Series housing
>
> Phil
>
> Federal Energy Regulatory Commission
> 888 First Street NE 41-72
> Washington DC 20426
> Philip.mudd@ferc.gov
> 202-502-646 desk
> 202-641-6001 cell